

SECTION 10 - TOILET FACILITIES

Toilet facilities shall be conveniently located and shall be accessible to employees at all times. They shall be easily cleanable.

Toilet facilities shall be installed according to **The North Carolina State Building Code, Volume II - Plumbing Code**. Consult with the building inspection department for more information and details.

As referenced by the North Carolina State Plumbing Code. Chapter P4 - **Plumbing Fixtures, Section P404 LOCATION OF FIXTURES, Paragraph P404.2 IMPROPER LOCATION:** Piping, fixtures, or equipment shall not be located in such a manner as to interfere with the normal operation of windows, doors, or other exit openings. Toilet rooms shall not open directly into a room used for the preparation of food for service to the public.

As referenced by the North Carolina State Plumbing Code. Chapter P4 - **Plumbing Fixtures, Section P407 MINIMUM FACILITIES, Paragraph P407.2.2** Every building and each subdivision thereof intended for public use shall be provided with facilities in accordance with this chapter. Required facilities shall be directly accessible to the public through direct openings or corridors from the area or areas they are intended to serve. Required facilities shall be free and designated by legible signs for each sex. Pay facilities may be installed when in excess of the required minimum facilities.

Toilet facilities shall be conveniently located, under control of the management, and readily accessible at all times. Toilets that are within 200 feet and on the same floor level of the facility is generally considered to be convenient.